P: 1 905 822 4111 F: 1 905 823 1446

 $info.toronto.industrials@element.com\\element.com$ 

# Dynamic Wind Uplift Resistance CSA A123.21-2020 – Summary Document

Document No.: 21-06-B0043-PARS019-A RV1

Document Date: October 26, 2021

element

Reference Documentation:

CSA A123.21-2014 Report No: 21-06-B0043-3 Supplementary Report No.: 19-06-B0042-M RV2

20-06-P0086

Manufacturer:	IKO Industries Ltd.	IKO System Identification:
	40 Hansen Road South	iko System identinication.
	Brampton, Ontario, Canada	PARS019
	L6W 3H4	PARSUIS

#### **SECTION 1.0: Roof System Summary:**

"IKO MOD-BIT – MECHANICALLY ATTACHED GYPSUM COVER BOARD" – Partially Attached Roofing System		
Roof Membrane - Cap Sheet:	IKO ArmourStick HD-Cap	
Roof Membrane – Base Sheet	IKO ArmourStick HD-Base	
Cover Board:	Georgia-Pacific DensDeck® Prime	
Insulation:	IKO IKOTherm™	
Insulation:	IKO IKOTherm™	
Vapour Retarder:	IKO MVP™ Vapour Retarder	
Thermal Barrier:	None	
Deck:	Steel Deck, 22 ga, RD938, 230 MPa (33.4 ksi)	

### SECTION 2.0: System Dynamic Wind Uplift Resistance (DUR) Testing Details:

Test Date	Dynamic Wind Uplift Resistance (DUR) of tested specimen kPa (psf)	Dynamic Wind Uplift Resistance (DUR)* Rating (with 1.5X safety factor) kPa (psf)
July 20, 2021	6.1 (127.5)	4.1 (85)

Dynamic Wind Uplift Resistance Rating (DUR): 4.1 kPa (85 psf)

## **SECTION 3.0: Tested Product and Substitutable Products:**

Roof Membrane (Cap Sheet)			
Tested Product	IKO ArmourStick HD-Cap		
Product Size	Roll Width 1 m (39.6"), Roll Length	8 m (26.2'), 4.5 mm (0.18" Thick) v	vith 90 mm (3.5") Overlap
Attachment Method	Self-adhered to base sheet		
Fastening Rate	n/a		
Substitutable Product(s)			
Manufacturer	Product Identification		
IKO Industries Ltd.	ArmourStick PrevENt		
	Torchflex TP-180-Cap	Torchflex TP-HD-Cap	Torchflex TP-250-Cap
	Torchflex TP-250-Cap (5 mm)	PrevENt TP-250-Cap	Torchflex Ultra TP-HD-Cap
IKO Industries Ltd.	PrevENt TP-HD-Cap	PrevENt Premium TP-250-Cap	ArmourCool Granular TP-HD
	PrevENt ArmourCool Granular TP	PrevENt ArmourCool HD Cap	Carrara ArmourCool HD
IKO Industrias Ltd	Modiflex MP-180-cap	Modiflex MP-250-cap	Modiflex MP-HD-cap
IKO Industries Ltd.	PrevENt MP-250-cap	PrevENt MP-HD-cap	

	Roof Membrane (Base Sheet)			
Tested Product	IKO ArmourStick HD-Base			
Product Size	Roll Width: 1 m (39.6"), roll Length	10 m (33'), 2.5 mm (0.0984" Thick) v	vith 90 mm (3.5") Overlap	
Attachment Method	Self-adhered to substrate primed w	ith IKO S.A.M. adhesive		
Fastening Rate	n/a			
	Substitutable Product(s)			
Manufacturer	Product Identification			
IKO Industries Ltd.	Torchflex TF-95-SF-Base	Torchflex TP-180-FF-Base	Torchflex TP-180-SF-Base	
IKO maustries Lta.	Torchflex HD-FF-Base	Torchflex Ultra TP-HD-FF-Base		
	Modiflex MF-95-FS-Base	Modiflex MF-95-SS-Base	Modiflex MP-180-FS-Base	
IKO Industries Ltd.	Modiflex MP-180-SS-Base	Modiflex MP-180-FS-Base 3mm	Modiflex MP-HD-FS-Base	
	Modiflex MP-HD-SS-Base			

	Cover Board		
Tested Product	GP DensDeck Prime		
Product Size	12.7 x 1220 x 2440 mm (1/2" x 4' x 8')		
Attachment Method	Mechanically attached		
Fastening Rate	1 per 2.00 ft² (0.19 m²)		
	Substitutable Product(s)		
Manufacturer	Product Identification		
n/a	n/a		



Insulation (Top Layer)			
Tested Product	IKO IKOTherm		
Product Size	38 x 1220 x 2440 mm (1.5" x 4' x	8')	
Attachment Method	Loose laid or pre-secured		
Fastening Rate	n/a		
	Substitu	utable Product(s)	
Manufacturer	Product Identification		
IKO Industrias Ltd	IKOTherm III	IKOTherm 25 psi	IKOTherm III 25 psi
IKO Industries Ltd.	IKOTherm Tapered	IKOTherm III Tapered	IKOTherm 25 psi Tapered

Insulation (Bottom Layer)			
Tested Product	IKO IKOTherm		
Product Size	38 x 1220 x 2440 mm (1.5" x 4' x	8')	
Attachment Method	Loose laid or pre-secured		
Fastening Rate	n/a		
	Substitutable Product(s)		
Manufacturer	Product Identification		
IVO Industrias Ltd	IKOTherm III	IKOTherm 25 psi	IKOTherm III 25 psi
IKO Industries Ltd.	IKOTherm Tapered	IKOTherm III Tapered	IKOTherm 25 psi Tapered

Vapour Retarder			
Tested Product	IKO MVP Vapour Retarder		
Product Size	Roll Width 1 m (39.4"), Roll Length 32 m (105')		
Attachment Method	Self-adhered to substrate	Self-adhered to substrate	
Fastening Rate	n/a		
	Substitutable Product(s)		
Manufacturer	Product Identification		
IKO Industries Ltd.	MVP Sand	Armourbond Flash Sand	

	Thermal Barrier			
Tested Product	Optional layer			
Product Thickness	n/a			
Attachment Method	Loose laid or pre-secured			
Fastening Rate	n/a			
	Substitutable Product(s)			
Manufacturer	Product Identification			
Georgia-Pacific®	DensDeck <sup>®</sup>	DensDeck Prime		
USG®/CGC	Securock® Glass-Mat	Securock® Gypsum-Fiber		
Generic	Any IKO approved Gypsum Board meeting the requirements of ASTM C1177 or ASTM C1278			



	Cover Board Securement		
Tested Product	IKO InnoviFast #14 All Purpose (AP) Fastener with InnoviFast 76 mm (3") Round Insulation Plate		
Fastening Rate	1 per 2.00 ft² (0.19 m²) - Sixteen (16) per 12.7 x 1220 x 2440 mm (0.5" x 4' x 8') board		
	Substitutional Product(s)		
Manufacturer	Product Identification		
SFS - Dekfast™	#14 Dekfast Fastener with 3" (76 mm) round (PLT-R-3) Metal Insulation Plate		
OMG <sup>®</sup>	#14 HD Roofing Fastener with 3" (76 mm) Galvalume Plate (SPGA3C)		
Trufast®	#14 HD Roofing Fastener with 76 mm (3") round (MP-3000) Metal Insulation Plate		

	Membrane Cap Sheet Securement	
Tested Product	ArmourStick HD-Cap	
Attachment Method	Self-adhered to base sheet	
Manufacturer	Substitute Product Attachment Method	
	ArmourStick PrevENt self-adhered to base sheet	
IKO Industries Ltd.	Torchflex and TP cap sheets heat welded to base sheet	
	Modiflex and MP cap sheets mopped to base sheet with hot asphalt	

Membrane Base Sheet Securement	
Tested Product	ArmourStick HD-Base
Attachment Method	Self-adhered to substrate primed with IKO S.A.M. adhesive
Manufacturer	Substitute Product Attachment Method
IKO Industries Ltd.	Torchflex, SF and FF base sheets heat welded to substrate primed with IKO Mod-Bit Primer
	Modiflex, FS and SS base sheets mopped with hot asphalt to substrate primed with IKO Standard Asphalt Primer

Note: This is not a comprehensive report but a <u>summary</u> of the performance results produced for the roof assembly documented herein tested in accordance to CSA A123.21-2020. Please refer to the reference documents stated on page 1, or consult the manufacturer, for detailed information pertaining to the test specimen configuration and construction.

Reported by:

Authorized by:

Allan Lawrence, Ext. 11212 Supervisor, Building Systems

Industrials Division

Jordan Church, B. Tech., Ext. 11546

Ops. / Tech. Manager, Bldg. Science & Fire Testing

Industrials Division

**Accreditation**: Element is an ISO 17025 accredited test lab under International Accreditation Service "TL-407". In addition, CSA A123.21 can be found under our scope of accreditation listing.

This report is related only to the sample identified and shall not be reproduced, except in full, without approval and is covered under Element Materials Technology Canada Inc. Standard Terms and Conditions of Contract, which is accessible at <a href="www.element.com">www.element.com</a>, or by calling 1-866-263-9268. Direct readings reported form the basis for acceptance or rejection (pass/fail) and do not take into account or incorporate uncertainty.