



- NOTES:
1. REFER TO IKO.COM/COMM FOR THE MOST UP TO DATE INSTALLATION INFORMATION.
 2. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL. IKO ASSUMES NO RESPONSIBILITY FOR THE INSTALLATION OF THE ASSOCIATED COMPONENTS OR DAMAGE TO THE ROOF SYSTEM DUE TO FAULTY INSTALLATION.
 3. MAXIMUM 10" (254 MM) LONG FASTENERS (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE THE FASTENER LENGTH TO MEET THIS REQUIREMENT).
 4. MINIMUM VERTICAL FLASHING HEIGHT OF 8" (200 MM) ABOVE THE FIELD MEMBRANE MUST BE ACHIEVED.
 5. TERMINATION NOT SHOWN IN THIS DRAWING; USE APPROPRIATE TERMINATION.
 6. IKO INNOVISEAL TPO EDGE SEALANT IS REQUIRED ON ALL CUT OR NON-ENCAPSULATED EDGES OF REINFORCED MEMBRANE. THIS INCLUDES FACTORY CUT EDGES.

Title: BASE FLASHING WITH CANT	Detail Number: T-BT-5
---------------------------------------	------------------------------

Issue Date: 8/01/2025	Maximum Warranty Term: 30-Years	Not to Scale
-----------------------	---------------------------------	--------------