



NOTE:

1. REFER TO IKO.COM/COMM FOR THE MOST UP TO DATE INSTALLATION INFORMATION.
2. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL. IKO ASSUMES NO RESPONSIBILITY FOR THE INSTALLATION OF THE ASSOCIATED COMPONENTS OR DAMAGE TO THE ROOF SYSTEM DUE TO FAULTY INSTALLATION.
3. MAXIMUM 10" (250 MM) LONG FASTENERS (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE THE FASTENER LENGTH TO MEET THIS REQUIREMENT.
4. MINIMUM VERTICAL FLASHING HEIGHT OF 8" (200 MM) ABOVE THE FIELD MEMBRANE MUST BE ACHIEVED.
5. IKO INNOVISEAL TPO EDGE SEALANT IS REQUIRED ON ALL CUT OR NON-ENCAPSULATED EDGES OF REINFORCED MEMBRANE. THIS INCLUDES FACTORY CUT EDGES.
6. IF A REINFORCED PERIMETER STRIP (RPS) IS USED AS THE BASE TIE-IN, THIS TYPE OF INSTALLATION IS LIMITED TO A 20-YEAR WARRANTY.

Title: TERMINATION AT R.T.U. WITH SEPARATE FLASHING (UNIT FLANGE MOUNTED TO SUBSTRATE)	Detail Number: T-CB-2
---	------------------------------

Issue Date: 8/01/2025	Maximum Warranty Term: 30-years	Not to Scale
------------------------------	--	---------------------