



NOTE:
 1. REFER TO IKO.COM/COMM FOR THE MOST UP TO DATE INSTALLATION INFORMATION.
 2. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL. IKO ASSUMES NO RESPONSIBILITY FOR THE INSTALLATION OF THE ASSOCIATED COMPONENTS OR DAMAGE TO THE ROOF SYSTEM DUE TO FAULTY INSTALLATION.
 3. MINIMUM VERTICAL FLASHING HEIGHT OF 8" (200 MM) ABOVE THE FIELD MEMBRANE MUST BE ACHIEVED.
 4. IKO INNOVISEAL TPO EDGE SEALANT IS REQUIRED ON ALL CUT OR NON-ENCAPSULATED EDGES OF REINFORCED MEMBRANE. THIS INCLUDES FACTORY CUT EDGES.

* = ROOFING GRADE AP SEALANT OR IKO INNOVISEAL CUT EDGE SEALANT

Title: TERMINATION AT R.T.U. WITH SEPARATE FLASHING (UNIT FLANGE ABOVE ROOF MEMBRANE)	Detail Number: <div style="font-size: 1.5em; font-weight: bold; text-align: center;">T-CB-3</div>
---	---

Issue Date: 8/01/2025	Maximum Warranty Term: 30-years	Not to Scale
-----------------------	---------------------------------	--------------