



NOTES:

1. REFER TO IKO.COM/COMM FOR THE MOST UP TO DATE INSTALLATION INFORMATION.
2. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL. IKO ASSUMES NO RESPONSIBILITY FOR THE INSTALLATION OF THE ASSOCIATED COMPONENTS OR DAMAGE TO THE ROOF SYSTEM DUE TO FAULTY INSTALLATION.
3. NAILERS SHOULD BE INSTALLED TO MEET ALL APPLICABLE BUILDING CODES.
4. IF THE SPAN BETWEEN THE PURLINS AT THE RIDGE EXCEEDS 5' (1524 MM) THEN ADDITIONAL MEMBRANE SECUREMENT MAY BE REQUIRED. WOOD BLOCKING AT OR NEAR THE RIDGE MAY BE REQUIRED.
5. THE RIDGE AREA MAY REQUIRE RIDGE BOARD INSULATION OR APPROPRIATE FOAM INSULATION TO FILL THE CAVITY.
6. APPLY INNOVISEAL TPO EDGE SEALANT AT ALL CUT OR EXPOSED MEMBRANE EDGES.
7. INSTALLED METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.

Title: ROOF RIDGE - EXISTING VENT CONDITION

Detail Number: T-T-13

Issue Date: 8/01/2025

Maximum Warranty Term: 20-Years

Not to Scale



COMMERCIAL

Specify with Confidence.

