



NOTES:

1. REFER TO IKO.COM/COMM FOR THE MOST UP TO DATE INSTALLATION INFORMATION.
2. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL. IKO ASSUMES NO RESPONSIBILITY FOR THE INSTALLATION OF THE ASSOCIATED COMPONENTS OR DAMAGE TO THE ROOF SYSTEM DUE TO FAULTY INSTALLATION.
3. TERMINATION BAR MUST BE CUT AT INSIDE AND OUTSIDE CORNERS. DO NOT BEND AROUND CORNERS.
4. TERMINATION BAR MUST BE TERMINATED WITHIN 1" (25 MM) MAXIMUM OF ALL SECTION ENDS.
5. METAL COUNTER FLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032 (0.81 MM) MINIMUM ALUMINUM.
6. ALL SEALANTS/CAULKING SHALL BE PERIODICALLY INSPECTED AND MAINTAINED BY THE BUILDING OWNER THROUGHOUT THE LIFE OF THE ROOF.
7. MINIMUM FLASHING HEIGHT IS 8" (203 MM) ABOVE THE ROOF SURFACE.
8. INSTALLED METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.

Title: TERMINATION BELOW EFIS OR WALL CLADDING

Detail Number:

T-T-6

Issue Date: 8/01/2025

Maximum Warranty Term: 20-Years

Not to Scale



COMMERCIAL

Specify with Confidence.

