

ACCEPTABLE SUBSTRATE

IKO INNOVISEAL  
WATERSTOP MASTIC

APPROPRIATE  
IKO INNOVIFAST  
FASTENER

1/4"

1/4"

IKO INNOVIFAST  
TERMINATION BAR

IKO INNOVISEAL GP SEALANT

IKO INNOVISEAL  
WATERSTOP MASTIC

IKO INNOVISEAL GP SEALANT

IKO INNOVI TPO MEMBRANE  
BELOW TERMINATION BAR

NOTES:

1. REFER TO IKO.COM/COMM FOR THE MOST UP TO DATE INSTALLATION INFORMATION.
2. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL. IKO ASSUMES NO RESPONSIBILITY FOR THE INSTALLATION OF THE ASSOCIATED COMPONENTS OR DAMAGE TO THE ROOF SYSTEM DUE TO FAULTY INSTALLATION.
3. TERMINATION BAR MUST BE TERMINATED WITHIN 1" (25 MM) MAXIMUM OF ALL SECTION ENDS.
4. ALL SEALANTS/CAULKING SHALL BE PERIODICALLY INSPECTED AND MAINTAINED BY THE BUILDING OWNER THROUGHOUT THE LIFE OF THE ROOF.
5. MINIMUM FLASHING HEIGHT IS 8" (203 MM) ABOVE THE ROOF SURFACE.

Title: TERMINATION BAR AT ELEVATION CHANGE

Detail Number:

T-T-7

Issue Date: 8/01/2025

Maximum Warranty Term: 20-Years

Not to Scale



**COMMERCIAL**

Specify with Confidence.

