


## Dynamic Wind Uplift Resistance CSA A123.21-20 – Summary Document

Document No.: 22-06-B0091-2-RV1-AARS027  
 Document Date: June 9, 2026

Reference Documentation:

CSA A123.21-20 Report No: 22-06-B0091-2  
 Supplementary Report No.: 22-06-B0109 (March 27, 2026)

<b>Manufacturer:</b>	IKO Industries Ltd.		<b>IKO System Identification:</b>
	40 Hansen Road South		
	Brampton, Ontario, Canada		
	L6W 3H4		<b>AARS027</b>

### SECTION 1.0: Roof System Summary:

"IKO SA Base Sheet to Glass Coated IKOTerm" – Adhesive Applied Roofing System	
Roof Membrane – Cap Sheet:	Torchflex TP-250-Cap
Roof Membrane – Base Sheet	Armourbond Flash
Insulation:	IKOTerm III
Insulation:	IKOTerm
Vapour Retarder:	MVP
Thermal Barrier:	DensDeck Prime
Deck:	Steel Deck, 22 ga, RD938, 230 MPa (33.4 ksi)

### SECTION 2.0: System Dynamic Wind Uplift Resistance (DUR) Testing Details:

Test Date	Measured Dynamic Wind Uplift Resistance of tested specimen, as per CSA A123.21-20 kPa (psf)	Dynamic Wind Uplift Resistance Rating, DUR (with 1.5X safety factor) as per CSA A123.21-14 kPa (psf)
September 16, 2022	5.03 (105.0)	3.35 (70.0)

**Measured Dynamic Wind Uplift Resistance: 5.03 kPa (105.0 psf)\***

\* Value does not include resistance factor. Applicable resistance factor shall be applied.

**SECTION 3.0: Tested Product and Substitutable Products:**

Roof Membrane (Cap Sheet)			
Tested Product	Torchflex TP-250-Cap		
Product Size	Roll Thickness: 4.0 mm (0.158"), Roll Width: 1.0 m (39.6"), Roll Length 8 m (26.2')		
Attachment Method	Heat Welded		
Substitutable Product(s)			
Manufacturer	Product Identification		
IKO Industries Ltd.	Torchflex TP-250-Cap 5 mm	Torchflex TP-HD-Cap	Torchflex Ultra TP-HD-Cap
	Armourcool Granular TP	Armourcool Granular TP-HD	Prevent TP-250-Cap
	Prevent TP-250-Cap 5mm	Prevent TP-HD-Cap	Prevent Premium TP-250-Cap
	Prevent Premium TP-HD-Cap	Prevent TP-HD-Cap 5mm	Armourcool Granular Prevent TP
	Armourcool Granular Prevent TP-HD	Armourcool Granular Prevent Premium TP	Armourcool Granular Prevent Premium TP-HD

Roof Membrane (Base Sheet)		
Tested Product	Armourbond Flash	
Product Size	Roll Thickness: 2.5 mm (0.098"), Roll Width: 1.0 m (39.6"), Roll Length 15 m (49')	
Attachment Method	Self-adhered	
Substitutable Product(s)		
Manufacturer	Product Identification	
IKO Industries Ltd.	Armourbond Flash HD	Armourbond 180

Cover Board		
Tested Product	Optional Layer	
Product Size	n/a	
Attachment Method	Ribbon adhered with IKO Millennium Adhesive	
Fastening Rate	305 mm (12") o.c.	
Substitutable Product(s)		
Manufacturer	Product Identification	
IKO Industries Ltd.	IKOTherm CoverShield (12.8 x 1220 x 1220 mm) (0.50" x 4' x 4')	
Georgia-Pacific	DensDeck Prime	
USG/CGC	Securock Gypsum-Fiber	

Insulation (Top Layer)			
Tested Product	IKO IKOTerm III		
Product Size	38 x 1220 x 1220 mm (1.5" x 4' x 4')		
Attachment Method	Ribbon adhered with IKO Millennium Adhesive		
Fastening Rate	305 mm (12") o.c.		
Substitutable Product(s)			
Manufacturer	Product Identification		
IKO Industries Ltd.	IKOTerm III 25 psi	IKOTerm III Tapered	

Insulation (Bottom Layer)			
Tested Product	IKO IKOTerm		
Product Size	38 x 1220 x 1220 mm (1.5" x 4' x 4')		
Attachment Method	Ribbon adhered with IKO Millennium adhesive		
Fastening Rate	305 mm (12") o.c.		
Substitutable Product(s)			
Manufacturer	Product Identification		
IKO Industries Ltd.	IKOTerm III	IKOTerm 25 psi	IKOTerm III 25 psi
	IKOTerm Tapered	IKOTerm III Tapered	IKOTerm Tapered 25 psi
	IKOTerm III Tapered 20 psi		

Vapour Retarder			
Tested Product	MVP		
Product Size	Roll Width 1 m (39.4"), Roll Length 32 m (105')		
Attachment Method	Self-adhered to substrate primed with IKO S.A.M. Adhesive		
Fastening Rate	n/a		
Substitutable Product(s)			
Manufacturer	Product Identification		
IKO Industries Ltd.	MVP Sand	Amourbond Flash Sand	AcrylicStick SA (Primerless)


Thermal Barrier			
Tested Product	DensDeck Prime		
Product Size	12.7 x 1220 x 2440 mm (1/2" x 4' x 8')		
Attachment Method	Ribbon adhered with IKO Millennium adhesive		
Fastening Rate	305 mm (12") o.c.		
Substitutable Product(s)			
Manufacturer	Product Identification		
USG®/CGC	Securock Gypsum-Fiber		

Cover Board/Insulation/Thermal Barrier Adhesive Securement	
Tested Product	IKO Millennium Adhesive – ribbon adhered
Fastening Rate	305 mm (12") o.c.
Substitutional Product(s)	
Manufacturer	Product Identification
n/a	n/a


*Note: This is not a comprehensive report but a summary of the performance results produced for the roof assembly documented herein tested in accordance to CSA A123.21-2020. Please refer to the reference documents stated on page 1, or consult the manufacturer, for detailed information pertaining to the test specimen configuration and construction.*

*The Substitutable Products referenced in this Element Summary Report have been established for IKO Industries as per Element Document 22-06-B0109 (March 26, 2026).*

**Approved by:**

  
Joe DeRose, P. Eng. Ext. 10221  
Technical Manager  
Building Science Division

**Reported by:**

  
Jordan Church, B. Tech., Ext. 11546  
General Manager  
Building Science Division

**Accreditation:** *Element is an ISO 17025 accredited test lab under A2LA. In addition, CSA A123.21 can be found under our scope of accreditation listing: 6524.01.*

*This report is related only to the sample identified and shall not be reproduced, except in full, without approval and is covered under Element Materials Technology Canada Inc. Standard Terms and Conditions of Contract, which is accessible at [www.element.com](http://www.element.com), or by calling 1-866-263-9268. Direct readings reported form the basis for acceptance or rejection (pass/fail) and do not take into account or incorporate uncertainty.*